Site inspection

Riverside Tower (sample) · Inspection before the level 12 pour

Date: 2026-11-25

Type: Before concrete pour

Area: Level 12, grid A to D

Inspector: Alex Morgan

No.	Item	Result	Photo	Remarks
1	Rebar spacing and cover	**Fail**		Cover below 40 mm at grid C3, blocks added.
2	Formwork alignment and props	**Pass**		
3	Cast-in items and sleeves	**Pass**		

Area ready for the next activity: No

Notes

Cover blocks added at grid C3 before the pour.

Photos

Inspector's signature